QUESTION FOR ANSWERS ON THE DAY
(but not taken up)

**Telephone Exchange at Hulsoor*

22. SRI BAPU RAO ANANDRAO (Basavakalyan) :—Will the Minister for Public Works be pleased to state :—

(*a*) whether the necessity to establish a Telephone Exchange at Hulsoor in Basavakalyan Taluk, Bidar District has come to the notice of the Government;

(*b*) if so, whether the Government have moved the authorities of the Post and Telegraphs Department in the matter ?

SRI H. M. CHANNABASAPPA (Minister for Public Works):—

(*a*) No

(*b*) Does not arise in view of reply to question (*a*).

†*Power required to run Various Plants of Mysore Iron and Steel Limited*

275. SRI A. K. ANWAR (Bhadravathi) :—Will the Minister for Industries and Parliamentary Affairs be pleased to state :—

(*a*) the total electric power required to run the M.I.S.L. (1) Ferro Silicon Plant (2) Electric Pig Iron Furnaces (3) Old Rolling Mill (4) Strip and Rod Mill (5) New Rolling Mills (6) Blooming Mills and other auxiliary Departments like foundries, Machine shop, Roll Turning Shop, L D Plant and other plants including Cement Plant (requirement of each Unit may be furnished separately);

(*b*) the plants affected by the power cut during this year ?

SRI S. M. Krishna (*Minister for Industries and Parliamentary Affairs*)

(a) The total electric power required to run the Mysore Iron and Steel Limited is detailed below :—

1.	Ferro Silicon Plant	30.00	M.W.
2.	Electric Pig Iron Furnaces	61.00	,,
3.	Old Roling Mills	0.75	,,
4.	Stip and Rod-Mills	0.45	,,
5.	New Rolling Mills	0.50	,,
6.	Blooming Mill	0.78	,,
7.	L. D. Plant	0.45	,,
8.	Auxiliary Departments and other plants :		
	(a) Oxygen Plant	1.29	,,
	(b) L. C. Plant	0.07	,,
	(c) I 20 Ton E.A.F. Axiliaries II 20 Ton E.A.F. Auxiliaries 8 Ton E.A.F. Auxiliaries	0.41	,,
	(d) Combined Bar and Rod Mill	1.06	,,
	(e) Pump House No. 2	0.30	,,
	(f) Roll Turning Shop	0.06	,,
	(g) Heat Treatment Shop	0.08	,,
	(h) Cement Plant	1.20	,,
	(i) General Foundry	0.04	,,
	(j) Machine Shop	0.08	,,
	(k) Pump House-I	0.50	,,
	(l) C.I.S.P.	0.06	,,
	(m) Plate Sleeper Foundry	0.05	,,
	(n) Open Hearth	0.09	,,
	(o) Old Rolling Mills Auxiliary	0 09	,,
	(p) Old E.P.I.F. Auxiliary	0.07	,,
	(q) Steel Foundry	0.11	,,
	(r) Lighting etc.	0.27	,,
	(s) Electric Arc Aurnances in Melting Shop	7.00	,,

(t) Electric Arc Furnaces in Steel Foundary 3.00

(*b*) The following plants have been completely shut down affecting production of Pig Iron, Ferro Silicon and Special and Alloy Steels.

	Units	*Shut down date* *From*	*To*	*Restarted*
1.	9,000 K.V.A. Ferro Silicon Furnace	24-6-1974	31-1-1975	1-2-1975
2.	12,000 K.V.A. -do-	23-11-1973	Till date	—
3.	1,500 K.V.A. Ferro Alloy Furnace.	2-10-1974	Till date	—
4.	13,200 K.V.A. Old Elec. Pig Iron Furnace.	12-9-1973	Till date	—
5.	One 20 Ton Elec. Arc Furnace of 6,000 K.V.A.	2-10-1974	Till date	

In addition, one old Elec. Pig Iron Furnace and two New Elec. Pig Iron Furnaces are being worked on partial load till date limiting the load to the amount of power made available.

CALLING ATTENTION TO A MATTER OF URGENT PUBLIC IMPORTANCE

re : taking up scarcity works in Afzalpur and Aland Taluks.

SRI D. B. KALMANKAR (Aland) :—I call the attention of the Minister for Revenue to the urgent need for taking up scarcity relief works in Afzalpur and Aland Taluk of Gulbarga District.

SRI B. SUBBIAH SHETTY (Minister of State for Land Reforms) on behalf of Hon'ble Minister for Revenue, I beg to state as :